





В

PROGRAMMARIE CONTROLLERS MILSELF



FX3U-16CCL-M INSTALLATION MANUAL



Manual Numi	Der JY997D43401
Revision	С
Date	April 2015

This manual describes the part names, dimensions, mounting, and specifications of the product. Before use, read this manual and the manuals of all relevant products fully to acquire proficiency in handling and operating the product. Make sure to learn all the product information, safety information, and precautions.

Store this manual in a safe place so that it can be taken out and read whenever necessary. Always forward it to the end user. Registration

The company and product names described in this manual are registered trademarks or the trademarks of their respective companies.

Effective April 2015

Specifications are subject to change without notice

© 2011 Mitsubishi Electric Corporation

Safety Precaution (Read these precautions before use.)

This manual classifies the safety precautions into two categories:

↑ WARNING and **↑** CAUTION

	Indicates that incorrect handling may cause hazardous conditions, resulting in death or severe injury.
∴CAUTION	Indicates that incorrect handling may cause hazardous conditions, resulting in medium or slight personal injury or physical damage.

Depending on the circumstances, procedures indicated by ACAUTION may also cause severe injury.

It is important to follow all precautions for personal safety.

Associated Manuals

Manual name	Manual No.	Description
FX3U-16CCL-M User's Manual	JY997D43601 MODEL CODE: 09R724	Describes details of the FX3U- 16CCL-M CC-Link master block.
FX3G Series User's Manual - Hardware Edition	JY997D31301 MODEL CODE: 09R521	Explains the FX3G Series PLC specifications for I/O, wiring, installation, and maintenance.
FX3U Series User's Manual - Hardware Edition	JY997D16501 MODEL CODE: 09R516	Explains the FX3U Series PLC specifications for I/O, wiring, installation, and maintenance.
FX3UC Series User's Manual - Hardware Edition	JY997D28701 MODEL CODE: 09R519	Explains the FX3UC Series PLC specifications for I/O, wiring, installation, and maintenance.
FX3S/FX3G/FX3GC/ FX3U/FX3UC Series Programming Manual - Basic & Applied Instruction Edition	JY997D16601 MODEL CODE: 09R517	Describes PLC programming for basic/applied instructions and devices.

How to obtain manuals

For product manuals or documents, consult with the Mitsubishi Electric dealer from who you purchased your product.

Certification of UL. cUL standards

EX31L16CCL-M units comply with the LII standards (LII cl.II.)

III cl II File Number: E95239

Regarding the standards that comply with the main unit please refer to either the EX series product catalog or consult with your nearest Mitsubishi product provider

Compliance with EC directive (CE Marking)

This note does not guarantee that an entire mechanical module produced in accordance with the contents of this note will comply with the following standards. Compliance to EMC directive and LVD directive for the entire mechanical module should be checked by the user / manufacturer. For more information please consult with your pearest Mitsubishi product provider

Regarding the standards that comply with the main unit, please refer to either the FX series product catalog or consult with your nearest Mitsubishi product provider.

Requirement for Compliance with EMC directive

The following products have shown compliance through direct testing (of the identified standards below) and design analysis (through the creation of a technical construction file) to the European Directive for Electromagnetic Compatibility (2004/108/EC) when used as directed by the appropriate documentation.

This product is designed for use in industrial applications.

 Authorized Representative in the European Community: Mitsubishi Electric Europe B V

Gothaer Str. 8, 40880 Ratingen, Germany

Programmable Controller (Open Type Equipment)

MELSEC FX3U series manufactured from August 1st. 2011 FX3U-16CCL-M


Standard	Remark
EN61131-2:2007 Programmable controllers - Equipment requiremen and tests	Compliance with all relevant aspects of the standard. SEMI Radiated Emission Conducted Emission EMS Radiated electromagnetic field Fast transient burst Electrostatic discharge High-energy surge Voltage drops and interruptions Conducted Fast

Caution for EC Directive

Installation in Enclosure


Programmable logic controllers are open-type devices that must be installed and used within conductive control cabinets. Please use the programmable logic controller while installed within a conductive shielded control cabinet. Please secure the cabinet door to the control cabinet (for conduction). Installation within a control cabinet greatly affects the safety of the system and aids in shielding noise from the programmable logic controller.

- Control cabinet
- The control cabinet must be conductive.
- Ground the control cabinet with the thickest possible grounding cable.
- To ensure that there is electric contact between the control cabinet and its door, connect the cabinet and its doors with thick wires.
- In order to suppress the leakage of radio waves, the control cabinet structure must have minimal openings. Also, wrap the cable holes with a shielding cover or other shielding devices.
- The gap between the control cabinet and its door must be as small as possible by attaching EMI gaskets between them.




*1 These wires are used to improve the conductivity between the door and control

Configuration example inside control cabinet




Wiring simplified diagram



Notes for compliance with EN61131-2:2007

General notes on the use of the power supply cable.

- The FX3U-16CCL-M unit requires that the cable used for power supply is 30 m or
- When the cable used for power supply exceeds 30 m, a noise filter (Ex. TDK-Lambda MBS1205-22 or similar) should be placed on the 24 V DC power cabling as close (within 500 mm) to the FX3U-16CCL-M termination points as possible. refer to following figure



1. Introduction

The CC-Link master block FX3U-16CCL-M is a special function block which assigns an FX3G/FX3U/FX3UC Series PLC as the master station of a CC-Link system. Only one FX3U-16CCL-M unit can be connected to a single programmable logic controller main unit

→ For details, refer to the FX3U-16CCL-M User's Manual.

1.1 Major Features of the FX3U-16CCL-M

- 1) Compatible with CC-Link Ver. 2.00 and Ver. 1.10 The FX3U-16CCL-M is compatible with CC-Link Ver. 2.00, and enables expanded cyclic transmission to facilitate the handling of applications requiring multiple points of data processing
- In addition to Ver. 2.00, Ver. 1.10 is also supported by the FX3U-16CCL-M.
- 2) The FX3U-16CCL-M supports connection of intelligent device stations Remote I/O stations, remote device stations and intelligent device station can also be connected to the FX3U-16CCL-M. [Caution]


Local stations can not be connected.

1.2 Incorporated Items

Check to ensure the following product and items are included in the package

Included Item			
FX3U-16CCL-M Special unit/block No. label		1 unit	
		1 sheet	
Terminal	For CC-Link dedicated cable 110 Ω 1/2 W (color cable: brown, brown and brown)	2 cables	
resistor	For CC-Link dedicated high-performance cable 130 Ω 1/2 W (color cable: brown, orange and brown)	2 cables	
Dust proof protection sheet		1 sheet	
Manuals (Ja	1 manual each		

1.3 External Dimensions and Part Names



MASS (Weight): 0.3 kg (0.66 lbs)

[1] Extension cable [7] DIN rail mounting hook

[2] Direct mounting hole Power supply terminal block 2 holes of 64.5 (0.18") (mounting screw: M4 screw)

[3] Power LED (green)

[9] Extension connector

[4] Status I FDs [5] Name plate

[10] CC-Link connection terminal block [11] Transmission rate setting switch


[6] DIN rail mounting groove (DIN rail: DIN46277. 35 mm (1.38") width)

[12] Station number setting switch

1.4 Power and status LEDs

LED display	LED Color	Status	Description
POWER	Green	OFF	Power is not being supplied from the external power supply (24 V DC).
TOWLK	Gleen	ON	Power is being supplied from the external power supply (24 V DC).
RUN	Green	OFF	FX3U-16CCL-M has failed.
KON	Oleen	ON	Under FX3U-16CCL-M normal operation.
		OFF	No errors.
ERR.	Red	Flicker	Communication error has occurred in some stations.
		ON	Communication error has occurred in all stations, error in the settings, error in the parameter details, error with the communication, error with the H/W.
L RUN	Green	OFF	Offline.
LRUN		ON	Data link is being executed (host station).
		OFF	No communication error.
L ERR.	Red	Flicker	The switch setting was changed after start. There is no terminating resistor. Influence from noise.
		ON	There is a data linking error (host station). There is a setting error.
SD	Green	OFF	Data is not being sent.
30	Green	ON	Data is being sent.
RD	Green	OFF	Data is not being received.
ND	Gieen	ON	Data is being received.

1.5 Terminal Layout



. Terminal screw and terminal block mounting screw size, and tightening torque Power supply terminal block, CC-Link connection terminal block:

M3 screw 0.42 to 0.58 Nem

CC-Link connection terminal block mounting screw (black):

M3.5 screw 0.66 to 0.91 Nem

CC-Link connection terminal block can be detached or attached. Make sure to cut off all phases of the power supply externally

For details on the wiring and the types of connection cables needed to connect to the terminal blocks shown in the figure above, refer to the following manual.

→ Refer to the FX3U-16CCL-M User's Manual.

1.6 Switch setting

With regard to the switch setting for station number transmission rate, line test hardware test, the switch settings become valid after EX3U-16CCL-M startun If the switch settings are changed after FX3U-16CCL-M startup, the L ERR, LED

To change the switch setting, power OFF the FX3U-16CCL-M once, and power it ON again

For details on the switch setting, refer to the following manual → Refer to the FX3II-16CCI -M User's Manual

1.6.1 Station number setting

Setting items	Range	Description
× 10	0,1	Online: 0 (Master station) Line test: 0 to 16
× 1	0 to 9	17 to 99 is the setting error.

1.6.2 Transmission rate setting, line test, hardware test

Setting	Description	Status
0	Transmission rate 156 Kbps	
1	Transmission rate 625 Kbps	
2	Transmission rate 2.5 Mbps	Online
3	Transmission rate 5 Mbps	
4	Transmission rate 10 Mbps	
5	Transmission rate 156 Kbps	Line test
6	Transmission rate 625 Kbps	When the station number setting switch is 0:
7	Transmission rate 2.5 Mbps	Line test 1
8	Transmission rate 5 Mbps	When the station number setting switch is 1 to 16:
9	Transmission rate 10 Mbps	Line test 2
Α	Transmission rate 156 Kbps	
В	Transmission rate 625 Kbps	
С	Transmission rate 2.5 Mbps	Hardware test
D	Transmission rate 5 Mbps	
E	Transmission rate 10 Mbps	
F	Unusable	Unusable

2. Installation

For details on installation, refer to the following manual.

→ Refer to the FX3U-16CCL-M User's Manual.

INSTALLATION **↑** WARNING PRECAUTIONS

Make sure to cut off all phases of the power supply externally before attempting installation work.

Failure to do so may cause electric shock or damage to the product.

INSTALL ATION **↑**CAUTION PRECAUTIONS

Use the product within the generic environment specifications described in PLC main unit manual (Hardware Edition)

Never use the product in areas with excessive dust, oily smoke, conductive dusts corrosive gas (salt air. Clz. HzS. SQz. or NQz), flammable gas, vibration of impacts, or expose it to high temperature, condensation, or rain and wind. If the product is used in such conditions, electric shock, fire, malfunctions

deterioration or damage may occur Do not touch the conductive parts of the product directly.

- Doing so may cause device failures or malfunctions
- Install the product securely using a DIN rail or mounting screws
- Install the product on a flat surface

If the mounting surface is rough, undue force will be applied to the PC board thereby causing nonconformities

- When drilling screw holes or wiring, make sure that cutting and wiring debris do not enter the ventilation slits
- Failure to do so may cause fire, equipment failures or malfunctions. Be sure to remove the dust proof sheet from the PLC's ventilation port when installation work is completed

Failure to do so may cause fire, equipment failures or malfunctions.

- Make sure to attach the top cover, offered as an accessory, before turning on the nower or initiating operation after installation or wiring work Failure to do so may cause electric shock
- Connect extension cables securely to their designated connectors. Loose connections may cause malfunctions

2.1 Connection with PLC

Only one EXXIL16CCL M can be connected to the right side of a PLC main unit or extension unit/block (including special function units/blocks).

For connection to an FX3UC Series PLC or FX2NC Series PLC extension block, an FX2NC-CNV-IF or FX3UC-1PS-5V is required.

For details, refer to the respective PLC manual.

- → Refer to the FX3G Series User's Manual Hardware Edition.
- → Refer to the FX3U Series User's Manual Hardware Edition
- → Refer to the FX3UC Series User's Manual Hardware Edition

2.2 Mounting

The product is mounted by the following method.

- DIN rail mounting
- . Direct mounting (mounting screw: M4 screw)

For details, refer to the respective PLC manual

- → Refer to the FX3G Series User's Manual Hardware Edition → Refer to the EX31 Series User's Manual - Hardware Edition
- → Refer to the FX3UC Series User's Manual Hardware Edition.

3. Specification

For details on specifications, refer to the following manual.

→ Refer to the FX3U-16CCL-M User's Manual.

DESIGN **⚠ WARNING** PRECAUTIONS

When executing control (data changes) to an operating PLC, construct an interlock circuit in the sequence program so that the entire system operates conservatively

In addition, when executing control such as program changes and operation status changes (status control) to an operating PLC, thoroughly read the manual and sufficiently confirm safety in advance

Especially in control from external equipment to a PLC in a remote place problems in the PLC may not be able to be handled promptly due to abnormality in data transfer

Construct an interlock circuit in the sequence program. At the same time, determine the actions in the system between the external equipment and the PLC for protection against abnormalities in data transfer

- Make sure to include the following safety circuits outside the PLC to ensure safe system operation even during external power supply problems or PLC failure. Otherwise, malfunctions may cause serious accidents
- 1)Above all, the following components should be included; an emergency stop circuit a protection circuit an interlock circuit for opposite movements (such as normal vs. reverse rotation), and an interlock circuit (to prevent damage to the equipment at the upper and lower positioning limits).
- 2) Note that when the PLC main unit detects an error during self diagnosis, such as a watchdog timer error, all outputs are turned off. Also, when an error that cannot be detected by the PLC main unit occurs in an input/output control block output control may be disabled

External circuits and mechanisms should be designed to ensure safe machinery operation in such cases.

↑CAUTION DECALITIONS

- Observe the following items. Failure to do so may cause incorrect data-writing through noise to the PLC and result in PLC failure, machine damage or other
- 1)Do not hundle the central line tegether with or lay it close to the main circuit or nower line. As a guideline, lay the control line at least 100 mm (3.94") or more away from the main circuit or nower line Noise may cause malfunctions
- 2)Ground the shield wire or shield of a shielded cable. Do not use common grounding with heavy electrical systems
- Do not apply excessive pressure to the power supply terminal block or CC-Link connection terminal block. Excessive pressure may cause damage or error

Nepoevi PRECAUTIONS

↑CAUTION

· Please contact a certified electronic waste disposal company for the environmentally safe recycling and disposal of your device.

TRANSPORTATION AND STOPAGE PRECAUTIONS

↑CAUTION

The PLC is a precision instrument. During transportation, avoid impacts larger than those specified in the general specifications of the PLC main unit manual Eailure to do so may cause failures in the PLC After transportation, verify the operations of the PLC.

3.1 Applicable PLC

Model name	Applicability
FX3G Series PLC	Ver. 1.00 and later Only one FX3U-16CCL-M unit can be connected in a main unit.
FX3U Series PLC	Ver. 2.20 and later Only one FX3U-16CCL-M unit can be connected in a main unit.
FX3UC Series PLC*1	Ver. 2.20 and later Only one FX3U-16CCL-M unit can be connected in a main unit.

The version number can be checked by reading the last three digits of device D8001/

*1 An FX2NC-CNV-IF or FX3UC-1PS-5V is necessary to connect the FX3U-16CCL-M with the EX3UC PLC

3.2 General Specifications

Items other than the following are equivalent to those of the PLC main unit. For general specifications, refer to the manual of the PLC main unit.

- → Refer to the FX3G Series User's Manual Hardware Edition.
- → Refer to the FX3U Series User's Manual Hardware Edition. → Refer to the FX3UC Series User's Manual - Hardware Edition.

Item		Specification	
	Dielectric withstand voltage	500 V AC for one minute	Between all terminals and ground
	Insulation resistance	5 M Ω or more by 500 V DC megger	terminal

3.3 Power Supply Specification

Item		Specification
	Power supply voltage	24 V DC +20% -15% Ripple (p-p) within 5%
External power supply	Permitted instantaneous power failure time	Operation continues when the instantaneous power failure is shorter than PS1:1 ms.
	Current consumption	240mA
	Power supply voltage	5 V DC of PLC is not used. (5 V DC is
Internal power supply	Current consumption	converted from 24 V DC external power supply.) Make sure to observe the power-on timing and the procedure.

3.4 Performance Specification

Item	Specification
Applicable function	Master station function (The local station and standby master station functions are not provided.)
CC-Link applicable version	Ver. 2.00 (Ver. 1.10 also supported.)
Station number	0 (set by rotary switch)
Transmission rate	156 Kbps/625 Kbps/2.5 Mbps/5 Mbps/10 Mbps (set by rotary switch)
Maximum total cable length (maximum transmission distance)	1,200 m maximum (varies depending on the transmission speed.) For details, refer to the FX3U-16CCL-M User's Manual.

	0 171 11
Item	Specification
Connection cable*1	CC-Link dedicated cable/ CC-Link dedicated high-performance cable/ Ver. 1.10 compatible CC-Link dedicated cable
Maximum number of connectable stations	Remote I/O stations: 8 maximum (Each stations occupies 32 I/O points of the PLC.) Remote device stations + Intelligent device stations: 8 maximum (The total number of RX/RY points is 256 or less.)
Maximum number of I/O points per system	When using an FX3U/FX3UC PLC 1) + 2) total number of Points ≤ 384 points 1) (Actual number of PLC I/O points) + (Number of points occupied by special function blocks) + (Number of points occupied by the FX3U-16CCL-Nic 8 points) ≥ 256 points 2) 32 × Number of remote I/O stations ≤ 256 points When using an FX3G PLC 32 × Number of remote I/O stations ≤ 128 points
Number of link points per station*2	Remote I/O (RX, RY): 32 points Remote register (RWw): 4 points (Master station → Remote device station/ intelligent device station) Remote register (RWr): 4 points (Remote device station/intelligent device station) → Master station)
Communication with PLC*3	By FROM and TO instructions or direct specification of buffer memory (FX3U/FX3UC) via the buffer memory.
Number of I/O occupied points	8 points
Number of connectable units to the main unit	1 (An FX3U-16CCL-M cannot be attached to main unit with an FX2N-16CCL-M.)

- *1 CC-Link dedicated cables, Ver. 1.10 compatible CC-Link dedicated cable and CC-I ink dedicated high-performance cable cannot be used together Also attach the terminating resister which matches the kind of the cable.
- *2 Indicates the number of link points for remote net ver. 1 mode. For the number of link points for remote net ver. 2 mode/remote net additional mode, refer to the FX3U-16CCL-M User's Manual.
- *3 For details of other applied instructions and methods, refer to the FX3S/ FX3G/FX3GC/FX3U/FX3UC Programming Manual

This manual confers no industrial property rights or any rights of any other kind, nor does it confer any patent licenses. Mitsubishi Electric Corporation cannot be held responsible for any problems involving industrial property rights which may occur as a result of using the contents noted in this manual.

Mitsubishi will not be held liable for damage caused by factors found not to be the cause of Mitsubishi; opportunity loss or lost profits caused by faults in the Mitsubishi products; damage, secondary damage, accident compensation caused by special factors unpredictable by Mitsubishi; damages to products other than Mitsubishi products: and to other duties

- This product has been manufactured as a general-purpose part for general industries, and has not been designed or manufactured to be incorporated in a device or system used in purposes related to human life.
- Before using the product for special purposes such as nuclear power, electric power, aerospace, medicine or passenger movement vehicles, consult with Mitsubishi Electric.
- This product has been manufactured under strict quality control. However when installing the product where major accidents or losses could occur if the product fails, install appropriate backup or failsafe functions in the system

MITSUBISHI ELECTRIC CORPORATION

HEAD OFFICE . TOKYO BUILDING 2-7-3 MARUNOLICHI CHIYODA-KU TOKYO 100-8310 JAPAN



Side



FX3U-16CCL-M INSTALLATION MANUAL



Manual Number	JY997D43401
Revision	С
Date	April 2015

This manual describes the part names, dimensions, mounting, and specifications of the product. Before use, read this manual and the manuals of all relevant products fully to acquire proficiency in handling and operating the product. Make sure to learn all the product information, safety information, and precautions. Store this manual in a safe place so that it can be taken out and read whenever necessary. Always forward it to the end user.

The company and product names described in this manual are registered trademarks or the trademarks of their respective companies.

Effective April 2015

Specifications are subject to change without notice

© 2011 Mitsubishi Electric Corporation

Safety Precaution (Read these precautions before use.) ual classifies the safety precautions into two categories

MARNING and **MCAUTION**

<u></u> MARNING	Indicates that

<u></u> MARNING	Indicates that incorrect handling may cause hazardous conditions, resulting in death or severe injury.
∴CAUTION	Indicates that incorrect handling may cause hazardous conditions, resulting in medium or slight personal injury or physical damage.

Depending on the circumstances, procedures indicated by ACAUTION may also cause severe injury.

It is important to follow all precautions for personal safety

Associated Manuals

Manual name	Manual No.	Description
FX3U-16CCL-M User's Manual	JY997D43601 MODEL CODE: 09R724	Describes details of the FX3U- 16CCL-M CC-Link master block.
FX3G Series User's Manual - Hardware Edition	JY997D31301 MODEL CODE: 09R521	Explains the FX3G Series PLC specifications for I/O, wiring, installation, and maintenance.
FX3U Series User's Manual - Hardware Edition	JY997D16501 MODEL CODE: 09R516	Explains the FX3U Series PLC specifications for I/O, wiring, installation, and maintenance.
FX3UC Series User's Manual - Hardware Edition	JY997D28701 MODEL CODE: 09R519	Explains the FX3UC Series PLC specifications for I/O, wiring, installation, and maintenance.
FX3S/FX3G/FX3GC/ FX3U/FX3UC Series Programming Manual - Basic & Applied Instruction Edition	JY997D16601 MODEL CODE: 09R517	Describes PLC programming for basic/applied instructions and devices.

How to obtain manuals
For product manuals or documents, consult with the Mitsubishi Electric dealer from who you purchased your product.

Certification of UL, cUL standards

FX3U-16CCL-M units comply with the UL stand UL, cUL File Number:E95239

Regarding the standards that comply with the main unit, please refer to either the FX series product catalog or consult with your nearest Mitsubishi product provider

Compliance with EC directive (CE Marking)

This note does not guarantee that an entire mechanical module produced in accordance with the contents of this note will comply with the following standards. Compliance to EMC directive and LVD directive for the entire mechanical module should be checked by the user / manufacturer. For more information please consult with your nearest Mitsubishi product provider. Regarding the standards that comply with the main unit, please refer to either the FX series product catalog or consult with your nearest Mitsubishi product provider.

Requirement for Compliance with EMC directive

The following products have shown compliance through direct testing (of the identified standards below) and design analysis (through the creation of a technical construction file) to the European Directive for Electromagnetic Compatibility (2004/108/EC) when used as directed by the appropriate documentation

- This product is designed for use in industrial applications
- Authorized Representative in the European Community:
 Mitsubishi Electric Europe B.V.
 Gothaer Str. 8, 40880 Ratingen, Germany

Type: Programmable Controller (Open Type Equipment)
Models: MELSEC FX3U series manufactured

from August 1st, 2011 FX3U-16CCL-M


Standard	кетагк
EN61131-2:2007	Compliance with all relevant aspects of the
Programmable controllers	standard.
 Equipment requirements 	EMI
and tests	Radiated Emission
	Conducted Emission
	EMS
	 Radiated electromagnetic field
	Fast transient burst
	Electrostatic discharge
	High-energy surge
	 Voltage drops and interruptions
	Conducted RF
	Dower frequency magnetic field

Caution for EC Directive

Installation in Enclosure


Programmable logic controllers are open-type devices that must be installed and used within conductive control cabinets. Please use the programmable logic controller while installed within a conductive shielded control cabinet. Please secure the cabinet door to the control cabinet (for conduction). Installation within a control cabinet greatly affects the safety of the system and aids in shielding noise from the programmable logic controller.

- Control cabinet
- The control cabinet must be conductive.
- Ground the control cabinet with the thickest possible grounding cable
- To ensure that there is electric contact between the control cabinet and its door, connect the cabinet and its doors with thick wires.
- In order to suppress the leakage of radio waves, the control cabinet structure must have minimal openings. Also, wrap the cable holes with a shielding cover or other shielding devices.
- The gap between the control cabinet and its door must be as small as possible by attaching EMI gaskets between them.




*1 These wires are used to improve the conductivity between the door and control

· Configuration example inside control cabinet



· Wiring simplified diagram



- Notes for compliance with EN61131-2:2007 General notes on the use of the power supp
- er supply cable The FX3U-16CCL-M unit requires that the cable used for power supply is 30 m or
- When the cable used for power supply exceeds 30 m, a noise filter (Ex. TDK-Lambda MB51205-22 or similar) should be placed on the 24 V DC power cabling as close (within 500 mm) to the FX3U-16CCL-M termination points as possible, refer to following figure.

		eeding 30 m	_	
FX3U-16CCL-M	500 mm or less	Noise	1	24 V DC power
24 V DC		Filter	\Longrightarrow	supply
	-			

1. Introduction

The CC-Link master block FX3U-16CCL-M is a special function block which assigns an FX3G/FX3U/FX3UC Series PLC as the master station of a CC-Link system.

Only one FX3U-16CCL-M unit can be connected to a single programmable logic controller main unit.

→ For details, refer to the FX3U-16CCL-M User's Manual.

Major Features of the FX3U-16CCL-M 1) Compatible with CC-Link Ver. 2.00 and Ver. 1.10

The EX3U-16CCI -M is compatible with CC-Link Ver 2.00, and enables expanded cyclic transmission to facilitate the handling of applications requiring multiple points of data processing. In addition to Ver. 2.00, Ver. 1.10 is also supported by the FX3U-16CCL-M.

2) The FX3U-16CCL-M supports connection of intelligent device stations
Remote I/O stations, remote device stations and intelligent device station can also
be connected to the FX3U-16CCL-M. [Caution]


Local stations can not be connected

1.2 Incorporated Items

Check to ensure the following product and items are included in the package

FX3U-16CCL	1 unit	
Special unit/	1 sheet	
Terminal resistor	For CC-Link dedicated cable 110 Ω 1/2 W (color cable: brown, brown and brown)	2 cables
	For CC-Link dedicated high-performance cable 130 Ω 1/2 W (color cable: brown, orange and brown)	2 cables
Dust proof p	1 sheet	
Manuals (Ja	1 manual each	

1.3 External Dimensions and Part Names



[1] Extension cable

[7] DIN rail mounting hook

[8] Power supply terminal block

[2] Direct mounting hole (mounting screw: M4 screw)

[3] Power LED (green) [4] Status LEDs

[9] Extension connector [10] CC-Link connection terminal block


[6] DIN rail mounting groove (DIN rail: DIN46277, 35 mm (1.38") width)

[12] Station number setting switch

1.4 Power and status LEDs

LED display	LED Color	Status	Description
POWER Green		OFF	Power is not being supplied from the externa power supply (24 V DC).
TOWER	Giccii	ON	Power is being supplied from the external powe supply (24 V DC).
RUN	Green	OFF	FX3U-16CCL-M has failed.
ROIT	Olccii	ON	Under FX3U-16CCL-M normal operation.
		OFF	No errors.
ERR.	Red	Flicker	Communication error has occurred in some stations.
		ON	Communication error has occurred in all stations error in the settings, error in the parameter details error with the communication, error with the H/W.
L RUN	Green	OFF	Offline.
LIKON		ON	Data link is being executed (host station).
	Red	OFF	No communication error.
L ERR.		Flicker	The switch setting was changed after start. There is no terminating resistor. Influence from noise.
		ON	There is a data linking error (host station). There is a setting error.
SD	Green	OFF	Data is not being sent.
05	Ciden	ON	Data is being sent.
RD	Green	OFF	Data is not being received.
110	Gideli	ON	Data is being received.

1.5 Terminal Layout



- Terminal screw and terminal block mounting screw size, and tightening torque Power supply terminal block, CC-Link connection terminal block: M3 screw, 0.42 to 0.58 Nem
 - on terminal block mounting screw (black):

M3.5 screw, 0.66 to 0.91 Nem

CC-Link connection terminal block can be detached or attached. Make sure to cut
off all phases of the power supply externally.

on all phases of the power supply externally.

For details on the wiring and the types of connection cables needed to connect to the terminal blocks shown in the figure above, refer to the following manual.

Refer to the FX3U-16CCL-M User's Manual.

With regard to the switch setting for station number, transmission rate, line test, hardware test, the switch settings become valid after FX3U-16CCL-M startup. If the switch settings are changed after FX3U-16CCL-M startup, the L ERR. LED

To change the switch setting, power OFF the FX3U-16CCL-M once, and power it

I again.
r details on the switch setting, refer to the following manual.
→ Refer to the FX3U-16CCL-M User's Manual. 1.6.1 Station number setting

Setting items	Range	Description
× 10	0,1	Online: 0 (Master station) Line test: 0 to 16
v 1	0 to 9	17 to 00 is the actting areas

1.6.2 Transmission rate setting, line test, hardware test

Settin	ıg	Description	Status		
0		Transmission rate 156 Kbps			
1		Transmission rate 625 Kbps			
2		Transmission rate 2.5 Mbps	Online		
3		Transmission rate 5 Mbps			
4		Transmission rate 10 Mbps			
5		Transmission rate 156 Kbps	Line test		
6		Transmission rate 625 Kbps	When the station number setting switch is 0:		
7		Transmission rate 2.5 Mbps	Line test 1		
8		Transmission rate 5 Mbps	When the station number setting switch is 1 to 16:		
9		Transmission rate 10 Mbps	Line test 2		
Α		Transmission rate 156 Kbps			
В		Transmission rate 625 Kbps			
С		Transmission rate 2.5 Mbps	Hardware test		
D		Transmission rate 5 Mbps			
Е		Transmission rate 10 Mbps			
F		Unucable	Unucable		

2. Installation

lation, refer to the following Refer to the FX3U-16CCL-M User's Manual

INSTALLATION PRECAUTIONS		⚠w	ARN	ING			
Make sure to attempting inst Failure to do so	allation wor	k.			,	,	before

ACAUTION

- Use the product within the generic environment specifications described in PLC main unit manual (Hardware Edition). Never use the product in areas with excessive dust, oily smoke, conductive dusts corrosive gas (salt air, Cl₂, H₂S, SO₂, or NO₂), flammable gas, vibration o impacts, or expose it to high temperature, condensation, or rain and wind. If the product is used in such conditions, electric shock, fire, malfunction
- deterioration or damage may occur.

 Do not touch the conductive parts of the product directly.

 Doing so may cause device failures or malfunctions.
- Install the product securely using a DIN rail or mounting screws.
- Install the product on a flat surface.

 If the mounting surface is rough, undue force will be applied to the PC boar thereby causing nonconformities.
- When drilling screw holes or wiring, make sure that cutting and wiring debris do not enter the ventilation slits
- Failure to do so may cause fire, equipment failures or malfunctions Be sure to remove the dust proof sheet from the PLC's ventilation port whe
- installation work is completed.

 Failure to do so may cause fire, equipment failures or malfunctions Make sure to attach the top cover, offered as an accessory, before turning on the
- power or initiating operation after installation or wiring work
- Failure to do so may cause electric shock.

 Connect extension cables securely to their designated connectors.

 Loose connections may cause malfunctions.

2.1 Connection with PLC

Only one FX3U-16CCL-M can be connected to the right side of a PLC main unit or extension unit/block (including special function units/blocks). For connection to an FX3UC Series PLC or FX2NC Series PLC extension block, an FX2NC-CNV-IF or FX3UC-1PS-5V is required.

For details, refer to the respective PLC manual.

Refer to the FX3G Series User's Manual - Hardware Edition.

Refer to the FX3U Series User's Manual - Hardware Edition.

Refer to the FX3U Series User's Manual - Hardware Edition.

2.2 Mounting The product is mounted by the following method.

- · DIN rail mounting
- Direct mounting (mounting screw: M4 screw)
 or details, refer to the respective PLC manual.

and sufficiently confirm safety in advance.

problems in the PLC may not be able to be handled pro

Otherwise, malfunctions may cause serious accidents

- - the respective PL∟ manual.

 → Refer to the FX3G Series User's Manual Hardware Edition.

 → Refer to the FX3U Series User's Manual Hardware Edition.

 → Refer to the FX3UC Series User's Manual Hardware Edition.

Specification

ails on specifications, refer to the following manual → Refer to the FX3U-16CCL-M User's Manual.

⚠WARNING

When executing control (data changes) to an operating PLC, construct an interlock circuit in the sequence program so that the entire system operates

In addition, when executing control such as program changes and operatio

status changes (status control) to an operating PLC, thoroughly read the manua

Especially in control from external equipment to a PLC in a remote place

in data transter.

Construct an interlock circuit in the sequence program. At the same tim determine the actions in the system between the external equipment and the PL for protection against abnormalities in data transfer.

Make sure to include the following safety circuits outside the PLC to ensure safe system operation even during external power supply problems or PLC failure.

2) Note that when the PLC main unit detects an error during self diagnosis, such

as a watchdog timer error, all outputs are turned off. Also, when an error that

	3. Specifica For details on spe
	DESIGN PRECAUTIONS
	When execut interlock circle
n number	In addition, w
n number 116:	status change and sufficientl Especially in problems in the in data transfe
	Construct an determine the for protection
	Make sure to system operat Otherwise, ma 1)Above all, the circuit, a proposition as normal versions.

1)Above all, the following components should be included: an emergency stop circuit, a protection circuit, an interlock circuit for opposite movements (such as normal vs. reverse rotation), and an interlock circuit (to prevent damage to the equipment at the upper and lower positioning limits).

cannot be detected by the PLC main unit occurs in an input/output control block output control may be disabled External circuits and mechanisms should be designed to ensure safe

⚠CAUTION RECAUTIONS

- Observe the following items. Failure to do so may cause incorrect data-writing through noise to the PLC and result in PLC failure, machine damage or other
- 1)Do not bundle the control line together with or lay it close to the main circuit or power line. As a guideline, lay the control line at least 100 mm (3.94") or more away from the main circuit or power line. Noise may cause malfunctions. 2)Ground the shield wire or shield of a shielded cable. Do not use commor
- grounding with heavy electrical systems. Do not apply excessive pressure to the power supply terminal block or CC-Link connection terminal block. Excessive pressure may cause damage or error.

DISPOSAL PRECAUTIONS	 ⚠ CAUTIO	N			
Please contact a certifie environmentally safe recycli			company	for	the

⚠CAUTION

The PLC is a precision instrument. During transportation, avoid impacts larger than those specified in the general specifications of the PLC main unit manual. Failure to do so may cause failures in the PLC. After transportation, verify the operations of the PLC.

3.1 Applicable PLC

Model name	Applicability
FX3G Series PLC	Ver. 1.00 and later Only one FX3U-16CCL-M unit can be connected in a main unit.
FX3U Series PLC	Ver. 2.20 and later Only one FX3U-16CCL-M unit can be connected in a main unit.
	Ver. 2.20 and later Only one FX3U-16CCL-M unit can be connected in a main unit.

The version number can be checked by reading the last three digits of device D8001/ D8101

*1 An FX2NC-CNV-IF or FX3UC-1PS-5V is necessary to connect the FX3U-16CCL-M with the FX3UC PLC.

3.2 General Specifications

→ Refer to the FX3G Series User's Manual - Hardware Edition
→ Refer to the FX3U Series User's Manual - Hardware Edition

→ Refer to the FX3UC Series User's Manual - Hardware Editi			
Item	Specification		
Dielectric withstand voltage	500 V AC for one minute	Between all terminals and ground	
Insulation	5 $\text{M}\Omega$ or more by 500 V	terminal	

3.3 Power Supply Specification

ltem		Specification	
	Power supply voltage	24 V DC +20% -15% Ripple (p-p) within 5%	
External power supply	Permitted instantaneous power failure time	Operation continues when the instantaneous power failure is shorter than PS1:1 ms.	
	Current consumption	240mA	
Internal power supply	Power supply voltage		
	Current consumption	converted from 24 V DC external power supply.) Make sure to observe the power-on timing and the procedure.	

3.4 Performance Specification

Item	Specification
Applicable function	Master station function (The local station and standby master station functions are not provided.)
CC-Link applicable version	Ver. 2.00 (Ver. 1.10 also supported.)
Station number	0 (set by rotary switch)
Transmission rate	156 Kbps/625 Kbps/2.5 Mbps/5 Mbps/10 Mbps (set by rotary switch)
Maximum total cable length (maximum transmission distance)	1,200 m maximum (varies depending on the transmission speed.) For details, refer to the FX3U-16CCL-M User's Manual.

Item	Specification	
Connection cable ^{*1}	CC-Link dedicated cable/ CC-Link dedicated high-performance cable/ Ver. 1.10 compatible CC-Link dedicated cable	
Maximum number of connectable stations	Remote I/O stations: 8 maximum (Each stations occupies 32 I/O points of the PLC.) Remote device stations + Intelligent device stations: 8 maximum (The total number of RX/RY points is 256 or less.)	
Maximum number of I/O points per system	When using an FX3u/FX3uc PLC 1) +2) total number of PLC 1/90 points ≤ 384 points 1) (Actual number of PLC 1/0 points) + (Number of points occupied by special function blocks) + (Number of points occupied by the FX3u-16CCL-W.18 points) ≥ 256 points 2) 32 × Number of remote I/O stations ≤ 256 points When using an FX3G PLC 32 × Number of remote I/O stations ≤ 128 points	
Number of link points per station ^{*2}	Remote I/O (RX, RY): 32 points Remote register (RWw): 4 points (Master station → Remote device station) Remote register (RWr): 4 points (Remote device station/intelligent devistation) → Master station)	
Communication with PLC*3	By FROM and TO instructions or direct specification of buffer memory (FX3U/FX3UC) via the buffer memory.	
Number of I/O occupied points	8 points	
Number of connectable units to the main unit	1 (An FX3U-16CCL-M cannot be attached to main unit with an FX2N-16CCL-M.)	

*1 CC-Link dedicated cables, Ver. 1.10 compatible CC-Link dedicated cable and CC-Link dedicated high-performance cable cannot be used together

Also attach the terminating resister which matches the kind of the cable *2 Indicates the number of link points for remote net ver. 1 mode. For the number of link points for remote net ver. 2 mode/remote net additiona

mode, refer to the FX3U-16CCL-M User's Manual. *3 For details of other applied instructions and methods, refer to the FX3S. FX3G/FX3GC/FX3U/FX3UC Programming Manual.

This manual confers no industrial property rights or any rights of any other kind, nor does it confer any patent licenses. Mitsubishi Electric Corporation cannot be held responsible for any problems involving industrial property rights which may occur as a result of using the contents noted in this manual.

warranty
Mitsubishi will not be held liable for damage caused by factors found not to be
the cause of Mitsubishi; opportunity loss or lost profits caused by faults in the
Mitsubishi products; damage, secondary damage, accident compensation
caused by special factors unpredictable by Mitsubishi; damages to products
other than Mitsubishi products; and to other duties.

en manufactured as a general-purpose part t	
not been designed or manufactured to be inc	

This product has be eneral This product has been intalinated as a givental-pulpose pain or general industries, and has not been designed or manufactured to be incorporated in a device or system used in purposes related to human life. Before using the product for special purposes such as nuclear power, electripower, aerospace, medicine or passenger movement vehicles, consult with

when installing the product where major accidents or losses could occur if the product fails, install appropriate backup or failsafe functions in the system.

MITSUBISHI ELECTRIC CORPORATION HEAD OFFICE: TOKYO BUILDING, 2-7-3 MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN